



Norman H. Bangerter
Governor

Suzanne Dandoy, M.D., M.P.H.
Executive Director

BAQE-102-87

December 7, 1987

Mr. Rodney Clark
Intermountain Power Project
Route 1, Box 824
Delta, Utah 84624

DIST	C
G. ROSE	X
V. BISHOP	
R. NIELSEN	X
J. TRAVIS	
C. SHY	
J. MUSTO	
V. SRIVASTAVA	
J. LYONS	
D. MURDOCK	
R. KRUSE	
S. HOLST	
D. BEGUIN	
B. MILES	
P. KENNEDY	
R. HANSEN	X
G. SHIPLEY	
C. FINNEGAN	
A. SPESARD	
SGC	X
FILE	0

*action
(write Reg.)*

w/attach
w/attach

action

*w/original invoice to make
payment*

w/attach

Dear Mr. Clark:

Re: Approval Order for Coal Sample Preparation Building
Millard County, CDS AI

The above-referenced project has been evaluated and found to be consistent with the requirements of the Utah Air Conservation Regulations (UACR) and the Utah Air Conservation Act. A 30-day public comment period was held and all comments received were evaluated. The conditions of this approval order reflect any changes to the proposed conditions which resulted from the evaluation of the comments received. This air quality approval order authorizes the project with the following conditions:

1. IPP shall install the coal sample preparation building according to the information submitted in the notice of intent dated June 17, 1987.
2. Visible emissions from any point or fugitive emission source associated with the installation or control facilities shall not exceed 20% opacity. Opacity observations of emissions from stationary sources shall be conducted in accordance with 40 CFR 60, Appendix A, Method 9.
3. All installations and facilities authorized by this approval order shall be adequately and properly maintained.
4. The Executive Secretary shall be notified upon start-up of the installation, as an initial compliance inspection is required.

SEE ALSO: 32.0408

99.9999.05.04

Kenneth L. Alkema, Director • Division of Environmental Health

288 North 1460 West • P.O. Box 16690 • Salt Lake City, Utah 84116-0690 • (801) 538-6121

RECEIVED

DEC 08 1987

I.P.P.

IP10_000113


Rodney Clark
Page 2

5. The particulate emissions generated from the coal processing (crushing, pulverizing, etc.) shall be controlled by fabric filter dust collector, Farr Tenkay, 8610 ACFM, or equivalent. Equivalency shall be determined by the Executive Secretary. The dust collector shall operate whenever coal is being processed.

Any future modifications to the equipment approved by this order must also be approved in accordance with Section 3.1.1, UACR.

The fee for issuing this approval order is \$344.80. The amount (see enclosure for breakdown of costs) is payable to the Utah Department of Health, sent to the Executive Secretary, Utah Air Conservation Committee, 288 North 1460 West, P.O. Box 16690, Salt Lake City, Utah 84116-0690 and is due within 30 days after receipt of this approval order. Please return payment in the enclosed self-addressed envelope.

Sincerely,


F. Burnell Corder
Executive Secretary
Utah Air Conservation Committee

FBC/DK/sh

cc: EPA Region VIII (John Dale)
Central Utah Health District